

INTERPRETATIONS & APPLICATIONS
OF BUILDING CODES & REGULATIONS #98-6

CODE SECTION : UBC 1003.3.1.3

02/10/98



SUBJECT : DOORWAYS

Doorways or other openings shall not exceed 24 inches in depth in the direction of travel.
Openings which exceed 24 inches in depth shall conform to the required exit width for corridors.

